

Public Document Pack



Chairman and Members of the
Development Management
Committee

Your contact: Peter Mannings
Tel: 01279 502174
Date: 11 March 2026

cc. All other recipients of the
Development Management
Committee agenda

Dear Councillor,

DEVELOPMENT MANAGEMENT COMMITTEE - 11 MARCH 2026

Please find attached the Additional Representations Summary and a table of report updates in respect of the following applications:

5. Planning Applications for Consideration by the Committee (Pages 3 – 4)
 - (A) 3/25/0950/FUL - Installation of 480 Photovoltaic Solar Panels, with an output of circa 240,000kWh of energy, with supporting infrastructure and landscaping works at Land at Aston End, Stevenage, Hertfordshire
 - (B) 3/25/0763/FUL - Change of use of land from blocked paved pedestrian area to provide 2 police vehicle car parking spaces, marked with studs and a sign (by way of Hertfordshire County Council Traffic Regulation Order) at Block Paved Area of Tudor Square, Ware, Hertfordshire, SG12 9XF

Yours faithfully,

Peter Mannings
Committee Support Officer
East Herts Council
peter.mannings@eastherts.gov.uk

MEETING : DEVELOPMENT MANAGEMENT COMMITTEE
VENUE : COUNCIL CHAMBER, WALLFIELDS, HERTFORD
DATE : WEDNESDAY 11 MARCH 2026
TIME : 7.00 PM

East Herts Council: Development Management Committee

Date: 11th March 2026

Summary of additional representations received after completion of reports submitted to the committee, but received by 5pm on the date of the meeting.

Agenda No	Summary of representations	Officer comments
5A	Hertfordshire Lead Local Flood Authority have suggested alternative surface water drainage conditions in light of scale of the proposal.	Condition 10 revised and condition 11 removed as agreed by LLFA – see below
5B	Ware Town Council have commented and have resolved to support the proposed development subject to the following concerns being noted: <ul style="list-style-type: none"> • Pedestrian safety • The availability of space for events in Tudor Square • The potential for the proposals to encourage additional parking in the square 	Officers consider these concerns to be addressed within the report submitted to committee and no amendments are made.

Table of errata and updates to reports submitted to Committee.

Agenda No	Paragraph No	Updates

5A		<p>Condition 10 updated to read as follows:</p> <p><i>Construction shall not begin until a detailed surface water drainage scheme for the site has been submitted to and approved in writing by the Local Planning Authority. The surface water drainage scheme must prioritise the use of source control Sustainable Drainage Systems (SuDS) in consideration of the Non-Statutory Technical Standards for SuDS and demonstrate no increase in flood risk as a result of the Proposed Development with sufficient supporting evidence provided to support its viability including supporting calculations for the 100% AEP (1 in 1 year), 3.33% AEP (1 in 30 year), 3.33% AEP (1 in 30 year) plus climate change, the 1% AEP (1 in 100 year) and the 1% AEP (1 in 100) plus climate change critical storms. The scheme shall subsequently be implemented in accordance with the approved details before the development is completed.</i></p> <p>Reason: <i>To ensure the flood risk is adequately addressed and not increased in accordance with NPPF and Policies of East Hertfordshire District Council.</i></p>
5A		<p>Condition 11 be removed and subsequent conditions be re-numbered accordingly.</p>
5A		<p>Addition of the following approved documents:</p> <p>PV system data sheet dated 22.8.24 – Myriad heat and power products Anchor system technical datasheet dated 09/21 by Solarport</p>